



AWT

Grille for installation in gymnasias and sports halls has a ball impact resistance conforming to DIN 18032 Part 3.
Robustly constructed supply or return air grille with fixed horizontal profiled blades with visible screw fixing (border counter punched).

TECHNOLOGY

rectangular

20 – 1,250 l/s
70 – 4,500 m³/h
42 – 2,648 cfm

L: 325 – 1,225 mm
H: 125 – 325 mm

Aluminium

