



## AWT

Grille for installation in gymnasias and sports halls has a ball impact resistance conforming to DIN 18032 Part 3.  
Robustly constructed supply or return air grille with fixed horizontal profiled blades with visible screw fixing (border counter punched).

## TECHNOLOGY

---

rectangular

20 - 1,250 l/s  
70 - 4,500 m<sup>3</sup>/h  
42 - 2,648 cfm

L: 325 - 1,225 mm  
H: 125 - 325 mm

Aluminium

